

# Introduction to Geothermal Power Plant Components (1)

Prepared by: Geocap Team & PPSDM EBTKE

Presented by: Khasani

*Training for Engineers on  
Geothermal Power Plant  
Yogyakarta, 9-13 October 2017*



# Basic concept of fluid separation and gathering

- When geothermal wells produce a mixture of steam and liquid, they must be separated using e.g. cylindrical cyclonic pressure vessel (separator).
- A piping system is needed to gather the geofluids from the production wells and transport them to the power house and to the points of disposal.









- Where the separator should be located is the challenging task for engineers.
- In general, the separator can be placed either close to the wellhead or power plant.



# Piping layouts



# Pressure losses

- One of the main concern in the design of the gathering system is the pressure loss in the steam lines from the wellhead to the powerhouse.
- The steam pressure drop is a function of the diameter, length, steam density, mass flow rate and configuration of the steam piping.
- The most critical variable is the pipe diameter, as indicated by the following equation.

$$\Delta P_f = 0.8 \frac{L \dot{m}^{1.85}}{\rho D^{4.97}}$$

- L = length of the pipe (ft)
- m = mass flow rate (lbm/h)
- $\rho$  = density (lbm/ft<sup>3</sup>)
- D = inside diameter (ft)



- The pressure drop in the liquid lines is less of a concern since the liquid is going to be disposed by injection.
- The frictional pressure drop depends on the same variables as in steam pipes plus friction factor which is a function of pipe diameter, internal roughness and the viscosity of the liquid.

$$\Delta P_f = 1.75 \times 10^{-4} \frac{f L \dot{m}^2}{\rho D^5}$$

$$f = \frac{0.25}{\left\{ \log_{10} \left[ \frac{\varepsilon/D}{3.7} + \frac{5.74}{\text{Re}^{0.9}} \right] \right\}^2}$$

$$\text{Re} = \frac{4}{\pi} \frac{\dot{m}}{\mu D}$$

- $\Delta P_f$  = pressure loss (lbf/in<sup>2</sup>)
- $\varepsilon$  = pipe internal roughness (ft)
- $\mu$  = absolute viscosity (lbm/ft.s)
- $D$  = inside diameter (ft)



- If there is a change in the elevation of the pipe, the gravity head must be included.

$$\Delta P_g = \rho g \Delta H$$

- $g$  = local gravitational acceleration (ft/s<sup>2</sup>)
- $\Delta H$  = change in elevation (ft)
- The pressure loss in a two-phase, steam-liquid pipeline is complex, and the empirical correlations are used to estimate the pressure drop.
- Sometimes, field tests are conducted to determine the losses experimentally.



- The pressure drop in the two-phase pipelines can be larger than that in single-phase pipelines.
- The presence of unsteady flow patterns such as slug flow can cause excessive vibrations and should be avoided by proper selection of the pipe diameters.
- The liquid leaving from the separator is in a saturated state, so any loss in pressure can cause it to flash into vapor and results in vibration, for example if the liquid is conveyed upward immediately after the separator.






- If the liquid is conveyed horizontally over significant distance, the frictional pressure drop may lead to flashing in the pipeline before the fluid reaches the injection well (vapor barrier).
- It is necessary to bleed vapor or to install booster pump.
- It is preferable to have the injection piping run downhill.

# Energy conversion system

- The flash process may occur in a number of places:
  - In **the reservoir** as the fluid flows through the permeable formation with an accompanying pressure drop
  - In **the production well** anywhere from the entry point to the wellhead as the result of pressure loss due to friction & gravity head
  - In **the inlet to the cyclone separator** as a result of throttling process by control valve or orifice.






- It is assumed that the geofluid starts off as a compressed liquid somewhere in the reservoir.
- It experiences flashing process somewhere, that the two-phases are separated.
- The steam is used to drive a turbine which in turn drives the electric generator.




# Thermodynamic of the conversion process

## Temperature-entropy process diagram



# Flashing process




## • State 1

- Geofluid under pressure close to the saturation curve.
- Flashing process is modeled as one at constant enthalpy ,i.e., isenthalpic (steadily, spontaneously, adiabatically with no work involvement).
- We neglect any change in the kinetic or potential energy.

$$h_1 = h_2$$



# Separation process



- State 2
  - The separation is modeled as one at constant pressure (isobar).
  - The quality (dryness fraction),  $x$ , of the mixture is found from

$$x_2 = \frac{h_2 - h_3}{h_4 - h_3}$$

- This gives the steam mass fraction of the mixture and is the amount of steam that goes to the turbine per unit total mass flow.



# Turbine expansion process (4-5)


- State 4
  - The work produced by the turbine per unit mass of steam

$$w_t = h_4 - h_5$$

assuming no heat loss from the turbine and neglecting kinetic and potential energy.

- The isentropic turbine efficiency  $\eta_t$ , as the ratio of the actual work to the isentropic work

$$\eta_t = \frac{h_4 - h_5}{h_4 - h_{5s}}$$





- The power developed by the turbine:

$$\dot{W}_t = \dot{m}_s w_t = x_2 \dot{m}_{total} w_t$$

- The gross electrical power:

$$\dot{W}_e = \eta_g \dot{W}_t$$

- All auxiliary power requirements (parasitic loads: pumping power, cooling tower fan power, etc.) for the plant must be subtracted from this to obtain the net, salable power.

- Since geothermal turbines generally operate in the wet region, we must account for the degradation in performance.
- The isentropic efficiency for a wet turbines:

$$\eta_{tw} = \eta_{td} \left[ \frac{x_4 + x_5}{2} \right]$$


$$\eta_{td} = 0.85 \text{ (dry turbine efficiency)}$$



- State 5

- The state depends on the turbine efficiency.
- For the ideal turbine outlet state:

$$h_{5s} = h_6 + [h_7 - h_6] \times \left[ \frac{s_4 - s_6}{s_7 - s_6} \right]$$



- For the actual turbine outlet state:

$$h_5 = \frac{h_4 - A \left[ 1 - \frac{h_6}{h_7 - h_6} \right]}{1 + \frac{A}{h_7 - h_6}}$$

$$A \equiv 0.425(h_4 - h_{5s})$$

- The above equations are based on the assumption that the quality at the turbine inlet,  $x_4 = 1$ , the steam is saturated vapor.
- If the inlet is wet:

$$h_5 = \frac{h_4 - A \left[ x_4 - \frac{h_6}{h_7 - h_6} \right]}{1 + \frac{A}{h_7 - h_6}} \quad (\text{for } x_4 < 1)$$




# Condensing process (5-6)

- State 6
  - The required flow rate of cooling water,  $\dot{m}_{cw}$ , to the steam flow rate,  $x_2 \dot{m}_{total}$ :

$$\dot{m}_{cw} = x_2 \dot{m}_{total} [\bar{c} \Delta T]$$

where  $c$  is the assumed constant specific heat of cooling water,  $\Delta T$  is the rise in cooling water temperature as it passes through the condenser.

- For a direct contact condenser, the appropriate equation:




$$\dot{m}_{cw} = x_2 \dot{m}_{total} \left[ \frac{h_5 - h_6}{\bar{c}(T_6 - T_{cw})} \right]$$

# Cooling tower process (7-8)

- State 7
  - The steam condensate that has been pumped from the condenser hotwell is sprayed into the tower where it falls through an air stream drawn into the tower by a motor driven fan at the top of the tower.
  - The internal process involves the exchange of both heat and mass between the air and the water.



- The overall operation of the tower, excluding the fan and assuming steady flow and overall adiabatic conditions:



$$\dot{m}_7 h_7 - \dot{m}_8 h_8 = \dot{m}_d h_d - \dot{m}_a h_a + \dot{m}_b h_b$$

- Conservation of water equation:

$$\dot{m}_7 - \dot{m}_{wa} = \dot{m}_8 + \dot{m}_b + \dot{m}_{wd}$$

- Conservation of dry air equation:

$$\dot{m}_{ad} = \dot{m}_{aa}$$

$\dot{m}_{wa}$  = water content of incoming air stream

$\dot{m}_{wd}$  = water content of leaving air stream

- The humidity of the air stream,  $\omega$ :

$$\dot{m}_{wa} = \omega_a \dot{m}_a$$

$$\dot{m}_{wd} = \omega_d \dot{m}_d$$



# Thank You

